

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1130:180

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Honeywell International Inc., 1500 W. Dundee Road, Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Models SIGA-CC1, SIGA-CC2, SIGA-CT1, SIGA-CT2, SIGA-CR, SIGA-CRR, SIGA-UM, SIGA-MM1, SIGA-WTM, SIGAS-IM, SIGA-MDM, SIGA-MAB, SIGA-MCT2, SIGA-MCC1, SIGA-MCR, SIGA-MCRR remote transponders; Models SIGA-AA30, SIGA-AA50 audio amplifiers; Models SIGA-APS, SIGA-APS-220 power supply and mounting plate Model SIGA-MB4; Models SIGA-UIO2R, SIGA-UIO and SIGA-UIO6R motherboards. Refer to listee's data sheet for additional detailed product description and operational consideration.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, and UL label.

APPROVAL: Listed as remote transponders for use with separately listed compatible fire alarm control units.

XLF: *7300-1591:121 Formerly 7300-1388:178

*Rev. 05-25-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**